

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242945  
Address: 3718 SW KNOXVILLE CT, LEES SUMMIT, MO 640823716 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Kyle Beard	Failed	Tuesday, November 19, 2024

Corrective Action Required:

1	Miscellaneous Correction	Fire rated roof sheathing at ridge in unit 3716 has a gap larger than 1/4 of an inch (Provide information on caulking used) 2x4's used at ridge are not considered applicable for a rated assembly
---	--------------------------	--

3718  
Better seal electrical service cable and bonding wire at demising wall

Comments: