

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20241067
Address: 2087 NW OBRIEN RD, LEES SUMMIT, MO 64081
Inspected On: Wednesday, November 20, 2024
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|-------------------|---------------------------------|
| Occupancy Inspection - Codes Residential | Robb Popp | Ready for Temp CO | Wednesday, November 20, 2024 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Complete final grade, sod, splash blocks etc. -Water meter to be 14" - 18" to top of riser -Remove mud from water meter pit |
|---|------|--|

Comments: