CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20222424

Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Pavement-Curb Construction Bobby Richest Partial Wednesday,

November 20, 2024

Informational:

1 Misc 10-21-24 BR Contractor poured concrete curbs on SE Cape Dr., SE, SE

Ranchland St., Falling Star Dr., SE Sweet Root Dr., SE Rising Sun Dr.

10-28-24 BR Contractor have to correct several storm boxes before pouring more concrete do to storm boxes are to high and need to be cut down to

meet curb level.

11-20-24 BR Contractor formed up curbs on SE Cape Dr. entrance with

aggregate and compacted. Ready for concrete.

Comments: