

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244072
Address: 3219 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, November 20, 2024

Corrective Action Required:
2 Misc

- Nail girder truss to code garage single bay
- Strap top plate over board load bearing wall at garage back of single bay 3" DWV
- Instal fireplace
- Provide attic access at single bay and other
- Provide security blocking at basement back door
- Provide anchor bolt at plate break basement sil north side
- Provide Truss D05 repair
- Strap top plate garage side at front entry wall

Comments: