

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242933
Address: 2218 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Thursday, November 21, 2024

Corrective Action Required:

1	Miscellaneous Correction	11/21/24 *Inspection for exterior garage PFH and dining CS-PF: -Solid block and nail horizontal seams at PFH -Splices in sheathing at CS-PF must be in middle 24" of panel height
---	--------------------------	--

Comments: