

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSITE20235268  
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Hydrostatic Test</b>	Bobby Richest	Partial	Friday, October 18, 2024

Informational:

1	Misc	10-18-24 BR Contractor (Selby Excavation) preformed hydrostatic test on water line A, line B, line G, line C at 150 psi which pass.
		11-12-24 BR Contractor (Selby Excavation) preformed hydrostatic test on water line D, line E at 150 psi for 2hr. which pass.

**Comments:**