

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20222424
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface	Bobby Richest	Partial	Thursday, November 21, 2024

Informational:

1	Misc	11-8-24 BR Contractor installed 5" of KCMMB A-3 asphalt base on Bailey Farms PKWY & SE Cape Dr. with 3rd party inspector (Ideker Inc.) getting 93 - 96 compaction.
		11-15-24 BR Contractor installed reminder 5" of KCMMB A-3 asphalt base on SE Cape Dr. with 3rd party inspector (Ideker Inc.) getting 94 - 96 compaction.
		11-21-24 BR Contractor poured concrete on SE Cape Dr. entrance with 9" of 4k KCMMB mix.

Comments: