

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241515
Address: 1605 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Thursday, November 21, 2024

Corrective Action Required:

1	Misc	-pay all fees -sod -splash blocks and sump pump discharge to extend 36" from foundation -uncover covered water meter Bring water meter well ring lid to grade(ensure water meter is 14 to 18 inches from top of meter to well, lid ring -identify sewer tracer wire
---	------	---

Comments: