

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241821
Address: 3220 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Thursday, November 21, 2024

Informational:
1 Misc

11-21-24 Dustin A, SW is formed and compacted. Will need to maintain ADA compliance. Approved to pour. Must cover over night and informed contractor that ground and air temp needs to be above freezing before they can pour.

Comments: