

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20230406  
Address: 1204 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                  | Inspector:  | Outcome: | Date:                       |
|------------------------------|-------------|----------|-----------------------------|
| <b>Punch List Inspection</b> | Devon Perry | Partial  | Thursday, November 21, 2024 |

Informational:

|   |      |  |
|---|------|--|
| 1 | Misc | 1-4-24 NS Site visited what all needs to be fixed<br>All will be spray painted.<br>ADA ramps<br>Road<br>Curbs<br>11-20-24 NS Site visited and what is in the inspection punch list is<br>Curb- multiple broken through out the subdivision<br>Road- has a small sink hole starting at the same place all other sink holes have been fixed.<br>Grass- seed has been put down around some areas but not all of it.<br>Detention Basin- needs to be cleaned out<br>Any mud on the streets need to be cleaned. |
|---|------|--|

**Comments:**