

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234141
Address: 400 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|---------------------------|
| Occupancy Inspection - Codes Commercial | Robb Popp | Failed | Friday, November 22, 2024 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Complete corrections for all other departments -Pay all fees due before occupancy (\$75 fee still outstanding) -Install accessible restroom signage -Provide code compliant address at building -Install expansion tank at water heater -Install grab bars at restroom per code/plans -Toilet to be max 16"-18" from side wall -Provide ASSE 1022 backflow device for carbonated beverage machines |
|---|------|--|

Comments: