

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240725
Address: 2219 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Ready for Temp CO	Friday, November 22, 2024

Corrective Action Required:

2	Miscellaneous Correction	-Address numbers are not illuminated -Install joist and beam support brackets at deck triple beam and last floor joist along the west side at platform -A couple of fasteners are missing in the joist hangers under the deck -Seal all exterior penetrations -Sod, splash pads and sump pump extension are not installed
---	--------------------------	---

Ok for TCO only

Comments: