## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20242599

Address: 1628 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Shawn Hoffman Not Ready Friday, November 22,

Residential 2024

Corrective Action Required:

1 Misc 1628 sw buckthorn

- provide guard for front porch (over 30" above grade)
- Second story sliding door with no deck built
- NO THERMOSTAT
- Inspection incomplete, too many life safety issues

**NOT READY** 

**Comments:**