

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243685
Address: 3111 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Failed	Friday, November 22, 2024

Corrective Action Required:

1	Misc	11-22-24 Dustin A, DW is formed, Aggregate was less than an inch in spots, Standing water in corner. Not compacted. Failed 11-22-24 Dustin A, Contractor dug it out , no compacter on site, Must recall. Fail
---	------	---

Comments: