

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243685  
Address: 3111 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Dustin Agcopra	Failed	Friday, November 22, 2024

Corrective Action Required:

1	Misc	11-22-24 Dustin A, DW is formed, Aggregate was less than an inch in spots, Standing water in corner. Not compacted. Failed 11-22-24 Dustin A, Contractor dug it out , no compacter on site, Must recall. Fail
---	------	---

**Comments:**