

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242275
Address: 630 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Robb Popp	Partial	Friday, November 22, 2024

Corrective Action Required:

1	Misc	Underground electrical OK below: -raceways to 2 north light poles, directional signage, Custard Icecream sign, and data -Conduit from transformer to building
---	------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: