

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242729  
Address: 3917 SW FLINTROCK DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                | Inspector:     | Outcome: | Date:                     |
|----------------------------|----------------|----------|---------------------------|
| <b>Sidewalk Inspection</b> | Dustin Agcopra | Partial  | Friday, November 22, 2024 |

Informational:  
1 Misc 11-22-24 Dustin A, SW is formed and compacted . Gravel was less then 4 inch but contractor corrected while i was there. Approved to pour. Slopes are in compliance

**Comments:**