

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244751  
Address: 1025 SW ARMIE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector:   | Outcome: | Date:                     |
|------------------------|--------------|----------|---------------------------|
| <b>Erosion Control</b> | Khanh Nguyen | Failed   | Monday, November 25, 2024 |

| Corrective Action Required:                                                                                |                                       |
|------------------------------------------------------------------------------------------------------------|---------------------------------------|
| 1                                                                                                          | DCM2 ESC<br>DEFICIENT<br>INSTALLATION |
| DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS<br>UNTIL ADEQUATE EROSION CONTROL PROVIDED. |                                       |

**Comments:**