

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242599  
Address: 1628 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Monday, November 25, 2024

Corrective Action Required:

2	Miscellaneous Correction	<ul style="list-style-type: none"><li>•Fire block gaps in sheet rock in garage above overhead doors</li><li>•Identify electrical receptacle in garage as non GFCI protected</li><li>•Thermostat not installed</li><li>•Nails missing for joist hanger on back deck</li><li>•Exterior A/C system s not installed</li><li>•Sod, splash pads and sump pump extension are not installed</li><li>•eal exterior penetrations</li><li>•Pay \$75 fee associated with this permit</li></ul>
---	--------------------------	--

Comments: