

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242186
Address: 3245 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Monday, November 25, 2024

Corrective Action Required:

1	Miscellaneous Correction	Fireplace is not installed Seal hole in garage ceiling sheet rock Secure garage overhead door track within 18 inches of floor Sod and splash pads are not installed Seal exterior penetrations Pay \$150 in fees associated with this permit
---	--------------------------	---

Comments: