

Structural Engineering & Design, Inc.

1815 Wright Ave
La Verne, CA 91750
Phone: 909.596.1351 Fax: 909.596.7186

Project Name : JOHNSON STORAGE AND MOVING

Project Number : 24-1119-12

Date : 11/21/24

Street Address: 2225 NE TOWNE CENTRE BLVD
City/State : LEE'S SUMMIT, MO 64064

Scope of Work : STORAGE RACKS



Structural Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: Johnson Storage

Project #: 24-1119

TABLE OF CONTENTS

12

Title Page	1
Table of Contents.....	2
Design Data and Definition of Components	3
Critical Configuration	4
Seismic Loads	5 to 6
Column	7
Beam and Connector	8 to 9
Bracing	10
Anchors	11
Base Plate	12
Slab on Grade	13
Other Configurations	14 to 17

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: Johnson Storage

Project #: 24-1119

Design Data

12

1) The analyses herein conforms to the requirements of the:
2018 IBC Section 2209

ANSI MH 16.1-2012 Specifications for the Design of Industrial Steel Storage Racks "2012 RMI Rack Design Manual"
ASCE 7-16, section 15.5.3

2) Transverse braced frame steel conforms to ASTM A570, Gr.55, with minimum strength, $F_y=55$ ksi
Longitudinal frame beam and connector steel conforms to ASTM A570, Gr.55, with minimum yield, $F_y=55$ ksi
All other steel conforms to ASTM A36, Gr. 36 with minimum yield, $F_y= 36$ ksi


3) Anchor bolts shall be provided by installer per ICC reference on plans and calculations herein.

4) All welds shall conform to AWS procedures, utilizing E70xx electrodes or similar. All such welds shall be performed in shop, with no field welding allowed other than those supervised by a licensed deputy inspector.


5) The existing slab on grade is 6" thick with minimum 4000 psi compressive strength. Allowable Soil bearing capacity is 750 psf. The design of the existing slab is by others.

6) Load combinations for rack components correspond to 2012 RMI Section 2.1 for ASD level load criteria

Definition of Components



Front View: Down Aisle
(Longitudinal) Frame



Section A: Cross Aisle
(Transverse) Frame

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186


By: Dray S

Project: **Johnson Storage**

Project #: **24-1119**

Configuration & Summary: TYPE A SELECTIVE RACK

12



**RACK COLUMN REACTIONS

ASD LOADS

AXIAL DL= 188 lb

AXIAL LL= 10,000 lb

SEISMIC AXIAL Ps= +/- 1,565 lb

BASE MOMENT= 0 in-lb

Seismic Criteria	# Bm Lvl	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=0.099, Fa=1.6	5	42 in	348.0 in	6	140 in	

Component		Description							STRESS
Column	Fy=55 ksi	INTLK LU75/3x3x13ga				P=10188 lb, M=14333 in-lb		0.91-OK	
Column & Backer	None	None				None		N/A	
Beam	Fy=55 ksi	Intlk 50E 5Hx2.75Wx0.059"Thk				Lu=140 in	Capacity: 4309 lb/pr	0.93-OK	
Beam Connector	Fy=55 ksi	Lvl 1: 3 pin OK		Mconn=10140 in-lb		Mcap=15230 in-lb		0.67-OK	
Brace-Horizontal	Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga							0.04-OK
Brace-Diagonal	Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga							0.18-OK
Base Plate	Fy=36 ksi	7.75x5x0.375					Fixity= 0 in-lb		0.97-OK
Anchor	2 per Base	0.5" x 3.25" Embed POWERS SD1 ESR 2818 No Inspection (Net Seismic Uplift=1066 lb)							0.517-OK
Slab & Soil		6" thk x 4000 psi slab on grade. 750 psf Soil Bearing Pressure							0.46-OK
Level	Load** Per Level	Beam Spcg	Brace	Story Force Transv	Story Force Longit.	Column Axial	Column Moment	Conn. Moment	Beam Connector
1	4,000 lb	66.0 in	52.0 in	24 lb	30 lb	10,188 lb	14,333 "#	10,140 "#	3 pin OK
2	4,000 lb	66.0 in	52.0 in	49 lb	61 lb	8,150 lb	7,008 "#	7,225 "#	3 pin OK
3	4,000 lb	66.0 in	73.0 in	73 lb	91 lb	6,113 lb	6,006 "#	6,349 "#	3 pin OK
4	4,000 lb	66.0 in	73.0 in	97 lb	121 lb	4,075 lb	4,505 "#	5,123 "#	3 pin OK
5	4,000 lb	66.0 in	73.0 in 12.0 in	121 lb	152 lb	2,038 lb	2,503 "#	3,547 "#	3 pin OK

** Load defined as product weight per pair of beams

Total: 364 lb 455 lb

Notes Std row spacers

Structural Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: **Johnson Storage**

Project #: **24-1119**

Seismic Forces Configuration: TYPE A SELECTIVE RACK

Lateral analysis is performed with regard to the requirements of the 2012 RMI ANSI MH 16.1-2012 Sec 2.6 & ASCE 7-16 sec 15.5.3

Transverse (Cross Aisle) Seismic Load

$$V = Cs \cdot Ip \cdot Ws = Cs \cdot Ip \cdot (0.67 \cdot P \cdot Prf + D)$$

$$Cs1 = Sds/R$$

$$= 0.0264$$

$$Cs2 = 0.044 \cdot Sds$$

$$= 0.0046$$

$$Cs3 = 0.5 \cdot S1/R$$

$$= 0.0085$$

$$Cs\text{-max} = 0.0264$$

$$\text{Base Shear Coeff} = Cs = \mathbf{0.0264}$$

$$Cs\text{-max} \cdot Ip = 0.0264$$

$$V_{min} = 0.015$$

$$\text{Eff Base Shear} = Cs = 0.0264$$

$$Ws = (0.67 \cdot PL_{RF1} \cdot PL) + DL \text{ (RMI 2.6.2)}$$

$$= 13,775 \text{ lb}$$

$$V_{transv} = Vt = \mathbf{0.0264 \cdot (375 \text{ lb} + 13400 \text{ lb})}$$

$$E_{transverse} = \mathbf{364 \text{ lb}}$$

Limit States Level Transverse seismic shear per upright



Transverse Elevation

$$Ss = 0.099$$

$$S1 = 0.068$$

$$Fa = 1.600$$

$$Fv = 2.400$$

$$Sds = 2/3 \cdot Ss \cdot Fa = 0.106$$

$$Sd1 = 2/3 \cdot S1 \cdot Fv = 0.109$$

$$Ca = 0.4 \cdot 2/3 \cdot Ss \cdot Fa = 0.0422$$

$$\text{(Transverse, Braced Frame Dir.) } R = 4.0$$

$$Ip = 1.0$$

$$P_{RF1} = 1.0$$

$$\text{Pallet Height} = hp = 48.0 \text{ in}$$

$$DL \text{ per Beam Lvl} = 75 \text{ lb}$$

Level	PRODUCT LOAD P	P*0.67*P _{RF1}	DL	hi	wi*hi	Fi	Fi*(hi+hp/2)
1	4,000 lb	2,680 lb	75 lb	66 in	181,830	24.3 lb	2,187-#
2	4,000 lb	2,680 lb	75 lb	132 in	363,660	48.5 lb	7,566-#
3	4,000 lb	2,680 lb	75 lb	198 in	545,490	72.8 lb	16,162-#
4	4,000 lb	2,680 lb	75 lb	264 in	727,320	97.1 lb	27,965-#
5	4,000 lb	2,680 lb	75 lb	330 in	909,150	121.3 lb	42,940-#

sum: P=20000 lb 13,400 lb 375 lb W=13775 lb 2,727,450 364 lb Σ=96,820

Longitudinal (Downaisle) Seismic Load

Similarly for longitudinal seismic loads, using R=6.0

$$Ws = (0.67 \cdot PL_{RF2} \cdot P) + DL$$

$$= 13,775 \text{ lb}$$

$$P_{RF2} = 1.0$$

$$\text{(Longitudinal, Unbraced Dir.) } R = 6.0$$

$$Cs1 = Sd1/(T \cdot R) = 0.0330$$

$$Cs2 = 0.0046$$

$$Cs3 = 0.0057$$

$$Cs\text{-max} = 0.0330$$


$$Cs = Cs\text{-max} \cdot Ip = 0.0330$$

$$T = 0.55 \text{ sec}$$

$$V_{long} = \mathbf{0.033 \cdot (375 \text{ lb} + 13400 \text{ lb})}$$

$$E_{longitudinal} = \mathbf{455 \text{ lb}}$$

Limit States Level Longit. seismic shear per upright



Front View

Level	PRODUC LOAD P	P*0.67*P _{RF2}	DL	hi	wi*hi	Fi
1	4,000 lb	2,680 lb	75 lb	66 in	181,830	30.3 lb
2	4,000 lb	2,680 lb	75 lb	132 in	363,660	60.7 lb
3	4,000 lb	2,680 lb	75 lb	198 in	545,490	91.0 lb
4	4,000 lb	2,680 lb	75 lb	264 in	727,320	121.3 lb
5	4,000 lb	2,680 lb	75 lb	330 in	909,150	151.7 lb

sum: 13,400 lb 375 lb W=13775 lb 2,727,450 455 lb

Structural Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: **Johnson Storage**

Project #: **24-1119**

Downsiale Seismic Loads


Configuration: TYPE A SELECTIVE RACK

12

Determine the story moments by applying portal analysis. The base plate is assumed to provide no fixity.

Seismic Story Forces

$$\begin{aligned} V_{long} &= 455 \text{ lb} \\ V_{col} &= V_{long}/2 = 228 \text{ lb} \\ F_1 &= 30 \text{ lb} \\ F_2 &= 61 \text{ lb} \\ F_3 &= 91 \text{ lb} \end{aligned}$$



Seismic Story Moments


Conceptual System

COL

$$\begin{aligned} M_{base-max} &= 0 \text{ in-lb} <==== \text{Default capacity} \\ M_{base-v} &= (V_{col} * h_{1eff})/2 \\ &= 7,166 \text{ in-lb} <==== \text{Moment going to base} \\ M_{base-eff} &= \text{Minimum of } M_{base-max} \text{ and } M_{base-v} \\ &= 0 \text{ in-lb} \text{ PINNED BASE ASSUMED} \\ M_{1-1} &= [V_{col} * h_{1eff}] - M_{base-eff} \\ &= (228 \text{ lb} * 63 \text{ in}) - 0 \text{ in-lb} \\ &= 14,333 \text{ in-lb} \end{aligned}$$

$$\begin{aligned} h_{1-eff} &= h_1 - \text{beam clip height}/2 \\ &= 63 \text{ in} \end{aligned}$$

$$\begin{aligned} M_{2-2} &= [V_{col} - (F_1)/2] * h_2 \\ &= [228 \text{ lb} - 30.4 \text{ lb}] * 66 \text{ in}/2 \\ &= 7,008 \text{ in-lb} \end{aligned}$$



$$M_{seis} = (M_{upper} + M_{lower})/2$$

$$\begin{aligned} M_{seis}(1-1) &= (14333 \text{ in-lb} + 7008 \text{ in-lb})/2 \\ &= 10,670 \text{ in-lb} \end{aligned}$$

$$\begin{aligned} M_{seis}(2-2) &= (7008 \text{ in-lb} + 6006 \text{ in-lb})/2 \\ &= 6,507 \text{ in-lb} \end{aligned}$$

$$\rho = 1.0000$$

Summary of Forces

LEVEL	hi	Axial Load	Column Moment**	Mseismic**	Mend-fixity	Mconn**	Beam Connector
1	66 in	10,188 lb	14,333 in-lb	10,670 in-lb	3,815 in-lb	10,140 in-lb	3 pin OK
2	66 in	8,150 lb	7,008 in-lb	6,507 in-lb	3,815 in-lb	7,225 in-lb	3 pin OK
3	66 in	6,113 lb	6,006 in-lb	5,255 in-lb	3,815 in-lb	6,349 in-lb	3 pin OK
4	66 in	4,075 lb	4,505 in-lb	3,504 in-lb	3,815 in-lb	5,123 in-lb	3 pin OK
5	66 in	2,038 lb	2,503 in-lb	1,252 in-lb	3,815 in-lb	3,547 in-lb	3 pin OK

$$\begin{aligned} M_{conn} &= (M_{seismic} + M_{end-fixity}) * 0.70 * \rho \\ M_{conn-allow}(3 \text{ Pin}) &= 15,230 \text{ in-lb} \end{aligned}$$

**all moments based on limit states level loading

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project:

Johnson Storage

Project #: 24-1119

Column (Longitudinal Loads)

Configuration: TYPE A SELECTIVE RACK

12

Section Properties

Section: INTLK LU75/3x3x13ga

$A_{eff} = 0.757 \text{ in}^2$

$I_x = 1.320 \text{ in}^4$

$S_x = 0.879 \text{ in}^3$

$r_x = 1.320 \text{ in}$

$\Omega_f = 1.67$

$E = 29,500 \text{ ksi}$

$I_y = 0.871 \text{ in}^4$

$S_y = 0.574 \text{ in}^3$

$r_y = 1.080 \text{ in}$

$F_y = 55 \text{ ksi}$

$C_{mx} = 0.85$


$K_x = 1.7$

$L_x = 63.5 \text{ in}$

$K_y = 1.0$

$L_y = 52.0 \text{ in}$

$C_b = 1.0$



Loads

Considers loads at level 1

COLUMN DL = 187 lb

COLUMN PL = 10,000 lb

$M_{col} = 14,332 \text{ in-lb}$

$S_{ds} = 0.1056$

$1 + 0.105 S_{ds} = 1.0111$

$1.4 + 0.14 S_{ds} = 1.4148$

$1 + 0.14 S_{ds} = 1.0148$

$0.85 + 0.14 S_{ds} = 0.8648$

$B = 0.7000$

$\rho = 1.0000$

Critical load cases are: RMI Sec 2.1

Load Case 5: $(1 + 0.105 S_{ds})D + 0.75(1.4 + 0.14 S_{ds})B^*P + 0.75(0.7 \rho E) \leq 1.0$, ASD Method

axial load coeff: $0.7427616 * P$

seismic moment coeff: $0.5625 * M_{col}$

Load Case 6: $(1 + 0.14 S_{ds})D + (0.85 + 0.14 S_{ds})B^*P + (0.7 \rho E) \leq 1.0$, ASD Method

axial load coeff: 0.60535

seismic moment coeff: $0.7 * M_{col}$

By analysis, Load case 5 governs utilizing loads as such

Axial Load = $P_{ax} = 1.011088 * 187 \text{ lb} + 0.75 * 1.414784 * 0.7 * 10000 \text{ lb}$
= 7,617 lb

Moment = $M_x = 0.75 * 0.7 \rho * M_{col}$
= $0.525 * 14332 \text{ in-lb}$
= 7,524 in-lb

Axial Analysis

$K_x L_x / r_x = 1.7 * 63.5 / 1.3196$
= 81.8

$K_y L_y / r_y = 1 * 52 / 1.08$
= 48.1

$F_e > F_y / 2$

$F_n = F_y (1 - F_y / 4 F_e)$
= $55 \text{ ksi} * [1 - 55 \text{ ksi} / (4 * 43.5 \text{ ksi})]$

= 37.6 ksi

$P_a = P_n / \Omega_c$

= $28477 \text{ lb} / 1.92$

= 14,832 lb

$F_e = \pi^2 E / (K L / r)^2$
= 43.5 ksi

$F_y / 2 = 27.5 \text{ ksi}$

$P_n = A_{eff} * F_n$
= 28,477 lb

$\Omega_c = 1.92$

$P / P_a = 0.51 > 0.15$

Bending Analysis

Check: $P_{ax} / P_a + (C_{mx} * M_x) / (M_{ax} * \mu_x) \leq 1.0$

$P / P_a + M_x / M_{ax} \leq 1.0$

$P_n = A_{eff} * F_y$

= $0.757 \text{ in}^2 * 55000 \text{ psi}$

= 41,635 lb

$P_{ao} = P_n / \Omega_c$

= $41635 \text{ lb} / 1.92$

= 21,685 lb

$M_{yield} = M_y = S_x * F_y$

= $0.879 \text{ in}^3 * 55000 \text{ psi}$

= 48,345 in-lb

$M_{ax} = M_y / \Omega_f$

= $48345 \text{ in-lb} / 1.67$

= 28,949 in-lb

$P_{cr} = \pi^2 EI / (K L)^2$

= $\pi^2 * 29500 \text{ ksi} / (1.7 * 63.5 \text{ in})^2$

= 32,980 lb

$\mu_x = \{1 / [1 - (\Omega_c * P / P_{cr})]\}^{-1}$

= $\{1 / [1 - (1.92 * 7617 \text{ lb} / 32980 \text{ lb})]\}^{-1}$

= 0.56

Combined Stresses

$(7617 \text{ lb} / 14832 \text{ lb}) + (0.85 * 7524 \text{ in-lb}) / (28949 \text{ in-lb} * 0.56) = 0.91 < 1.0, \text{ OK (EQ C5-1)}$

$(7617 \text{ lb} / 21685 \text{ lb}) + (7524 \text{ in-lb} / 28949 \text{ in-lb}) = 0.61 < 1.0, \text{ OK (EQ C5-2)}$

** For comparison, total column stress computed for load case 6 is: 88.0%

g loads 6243.252608 lb Axial and $M = 10032 \text{ in-lb}$

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: Johnson Storage

Project #: 24-1110

BEAM

Configuration: TYPE A SELECTIVE RACK

12


DETERMINE ALLOWABLE MOMENT CAPACITY

A) Check compression flange for local buckling (B2.1)

$$\begin{aligned} w &= c - 2*t - 2*r \\ &= 1.75 \text{ in} - 2*0.059 \text{ in} - 2*0.059 \text{ in} \\ &= 1.514 \text{ in} \\ w/t &= 25.66 \\ l=\lambda &= [1.052/(k)^{0.5}] * (w/t) * (F_y/E)^{0.5} \\ &= [1.052/(4)^{0.5}] * 25.66 * (55/29500)^{0.5} \\ &= 0.583 < 0.673, \text{ Flange is fully effective} \end{aligned}$$

Eq. B2.1-4

Eq. B2.1-1



B) check web for local buckling per section b2.3

$$\begin{aligned} f_1(\text{comp}) &= F_y * (y_3/y_2) = 51.18 \text{ ksi} \\ f_2(\text{tension}) &= F_y * (y_1/y_2) = 102.95 \text{ ksi} \\ Y &= f_2/f_1 \\ &= -2.012 \\ k &= 4 + 2*(1-Y)^3 + 2*(1-Y) \\ &= 64.67 \\ \text{flat depth} &= w = y_1 + y_3 \\ &= 4.764 \text{ in} \\ w/t &= 80.74576271 \text{ OK} \\ l=\lambda &= [1.052/(k)^{0.5}] * (w/t) * (f_1/E)^{0.5} \\ &= [1.052/(64.67)^{0.5}] * 4.764 * (51.18/29500)^{0.5} \\ &= 0.44 < 0.673 \\ b_e &= w = 4.764 \text{ in} \\ b_2 &= b_e/2 = 2.38 \text{ in} \\ b_1 &= b_e(3-Y) = 0.951 \text{ in} \\ b_1 + b_2 &= 3.331 \text{ in} > 1.582 \text{ in, Web is fully effective} \end{aligned}$$

Eq. B2.3-5

Eq. B2.3-4

OK

Eq B2.3-2

Beam= Intlk 50E 5Hx2.75Wx0.059"Thk

I_x	2.916 in ⁴
S_x	1.114 in ³
Y_{cg}	3.300 in
t	0.059 in
Bend Radius= r	0.059 in
$F_y = F_{yv}$	55.00 ksi
$F_u = F_{uv}$	65.00 ksi
E	29500 ksi
top flange= b	1.750 in
bottom flange= b	2.750 in
Web depth= d	5.000 in

Determine effect of cold working on steel yield point (F_y) per section A7.2


$$\begin{aligned} F_{ya} &= C * F_{yc} + (1-C) * F_y \quad (\text{EQ A7.2-1}) \\ L_{\text{corner}} &= L_c = (p/2) * (r + t/2) \\ &= 0.139 \text{ in} \\ C &= 2 * L_c / (L_f + 2 * L_c) \\ L_{\text{flange-top}} &= L_f = 1.514 \text{ in} \\ &= 0.155 \text{ in} \\ m &= 0.192 * (F_u/F_y) - 0.068 \quad (\text{EQ A7.2-4}) \\ &= 0.1590 \\ B_c &= 3.69 * (F_u/F_y) - 0.819 * (F_u/F_y)^2 - 1.79 \\ &= 1.427 \\ \text{since } f_u/F_y &= 1.18 < 1.2 \\ \text{and } r/t &= 1 < 7 \text{ OK} \\ \text{then } F_{yc} &= B_c * F_y / (R/t)^m \quad (\text{EQ A7.2-2}) \\ &= 78.485 \text{ ksi} \end{aligned}$$

$$\begin{aligned} \text{Thus, } F_{ya-\text{top}} &= 58.64 \text{ ksi} \quad (\text{tension stress at top}) \\ F_{ya-\text{bottom}} &= F_{ya} * Y_{cg} / (\text{depth} - Y_{cg}) \\ &= 113.84 \text{ ksi} \quad (\text{tension stress at bottom}) \end{aligned}$$

Check allowable tension stress for bottom flange

$$\begin{aligned} L_{\text{flange-bot}} &= L_{fb} = L_{\text{bottom}} - 2 * r - 2 * t \\ &= 2.514 \text{ in} \\ C_{\text{bottom}} &= C_b = 2 * L_c / (L_{fb} + 2 * L_c) \\ &= 0.100 \\ F_{y-\text{bottom}} &= F_{yb} = C_b * F_{yc} + (1-C_b) * F_y \\ &= 57.34 \text{ ksi} \\ F_{ya} &= (F_{ya-\text{top}}) * (F_{yb} / F_{ya-\text{bottom}}) \\ &= 29.54 \text{ ksi} \\ \text{if } F &= 0.95 \end{aligned}$$

$$\text{Then } F * M_n = F * F_{ya} * S_x = 31.26 \text{ in-k}$$



$$\begin{aligned} y_1 &= Y_{cg} - t - r = 3.182 \text{ in} \\ y_2 &= \text{depth} - Y_{cg} = 1.700 \text{ in} \\ y_3 &= y_2 - t - r = 1.582 \text{ in} \end{aligned}$$

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: **Johnson Storage**

Project #: **24-1119**

BEAM


Configuration: TYPE A SELECTIVE RACK

12

RMI Section 5.2, PT II

Section

Beam= Intlk 50E 5Hx2.75Wx0.059"Thk
 $I_x = I_y = 2.916 \text{ in}^4$
 $S_x = 1.114 \text{ in}^3$
 $t = 0.059 \text{ in}$
 $E = 29500 \text{ ksi}$
 $F_y = F_{yv} = 55 \text{ ksi}$
 $F_u = F_{uv} = 65 \text{ ksi}$
 $F_{ya} = 58.6 \text{ ksi}$
 $F = 240.0$
 $L = 140 \text{ in}$
 Beam Level= 1
 $P = \text{Product Load} = 4,000 \text{ lb/pair}$
 $D = \text{Dead Load} = 75 \text{ lb/pair}$



1. Check Bending Stress Allowable Loads

$$M_{center} = F \cdot M_n = W \cdot L \cdot W \cdot R_m / 8$$

W=LRFD Load Factor= $1.2 \cdot D + 1.4 \cdot P + 1.4 \cdot (0.125) \cdot P$
FOR DL=2% of PL,

RMI 2.2, item 8

$$W = 1.599$$

$$R_m = 1 - [(2 \cdot F \cdot L) / (6 \cdot E \cdot I_b + 3 \cdot F \cdot L)]$$

$$= 1 - (2 \cdot 240 \cdot 140 \text{ in}) / [(6 \cdot 29500 \text{ ksi} \cdot 2.9155 \text{ in}^4) + (3 \cdot 240 \cdot 140 \text{ in})]$$

$$= 0.891$$

$$\text{if } F = 0.95$$

$$\text{Then } F \cdot M_n = F \cdot F_{ya} \cdot S_x = 62.06 \text{ in-k}$$

Thus, allowable load

$$\text{per beam pair} = W = F \cdot M_n \cdot 8 \cdot (\# \text{ of beams}) / (L \cdot R_m \cdot W)$$

$$= 62.06 \text{ in-k} \cdot 8 \cdot 2 / (140 \text{ in} \cdot 0.891 \cdot 1.599)$$


$$= \mathbf{4,979 \text{ lb/pair}} \quad \text{allowable load based on bending stress}$$

$$M_{end} = W \cdot L \cdot (1 - R_m) / 8$$

$$= (4979 \text{ lb/2}) \cdot 140 \text{ in} \cdot (1 - 0.891) / 8$$

$$= 4,749 \text{ in-lb} \quad @ \text{ 4979 lb max allowable load}$$

$$= 3,815 \text{ in-lb} \quad @ \mathbf{4000 \text{ lb imposed product load}}$$



2. Check Deflection Stress Allowable Loads

$$D_{max} = D_{ss} \cdot R_d$$

$$R_d = 1 - (4 \cdot F \cdot L) / (5 \cdot F \cdot L + 10 \cdot E \cdot I_b)$$

$$= 1 - (4 \cdot 240 \cdot 140 \text{ in}) / [(5 \cdot 240 \cdot 140 \text{ in}) + (10 \cdot 29500 \text{ ksi} \cdot 2.9155 \text{ in}^4)]$$

$$= 0.869 \text{ in}$$

$$\text{if } D_{max} = L / 180 \quad \text{Based on } L/180 \text{ Deflection Criteria}$$

$$\text{and } D_{ss} = 5 \cdot W \cdot L^3 / (384 \cdot E \cdot I_b)$$

$$\text{Allowable Deflection} = L / 180$$

$$= 0.778 \text{ in}$$

$$\text{Deflection at imposed Load} = 0.722 \text{ in}$$

$$L / 180 = 5 \cdot W \cdot L^3 \cdot R_d / (384 \cdot E \cdot I_b \cdot \# \text{ of beams})$$

solving for W yields,

$$W = 384 \cdot E \cdot I_b^2 / (180 \cdot 5 \cdot L^2 \cdot R_d)$$

$$= 384 \cdot 2.9155 \text{ in}^4 \cdot 2 / [180 \cdot 5 \cdot (140 \text{ in})^2 \cdot 0.869]$$

$$= \mathbf{4,309 \text{ lb/pair}} \quad \text{allowable load based on deflection limits}$$

Thus, based on the least capacity of item 1 and 2 above:

Allowable load= 4,309 lb/pair
Imposed Product Load= 4,000 lb/pair
Beam Stress= 0.93

Beam at Level 1

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: S

Project: **Johnson Storage**

Project #: **24-1119**

3 Pin Beam to Column Connection


TYPE A SELECTIVE RACK

12

The beam end moments shown herein show the result of the maximum induced fixed end moments from seismic + static loads and the code mandated minimum value of 1.5%(DL+PL)

$$\begin{aligned} M_{conn \max} &= (M_{seismic} + M_{end-fixity}) * 0.70 * \rho \\ &= 10,140 \text{ in-lb} \quad \text{Load at level 1} \end{aligned}$$

$$\rho = 1.0000$$



Connector Type= 3 Pin

Shear Capacity of Pin

Pin Diam= 0.44 in

Fy= 55,000 psi

$$\begin{aligned} A_{shear} &= (0.438 \text{ in})^2 * \pi / 4 \\ &= 0.1507 \text{ in}^2 \end{aligned}$$

$$\begin{aligned} P_{shear} &= 0.4 * F_y * A_{shear} \\ &= 0.4 * 55000 \text{ psi} * 0.1507 \text{ in}^2 \\ &= 3,315 \text{ lb} \end{aligned}$$

Bearing Capacity of Pin

tcol= 0.090 in

Fu= 65,000 psi

Omega= 2.22

a= 2.22

$$\begin{aligned} P_{bearing} &= \alpha * F_u * \text{diam} * t_{col} / \Omega \\ &= 2.22 * 65000 \text{ psi} * 0.438 \text{ in} * 0.09 \text{ in} / 2.22 \\ &= 2,562 \text{ lb} < 3315 \text{ lb} \end{aligned}$$

Moment Capacity of Bracket

Edge Distance=E= 1.00 in

Pin Spacing= 2.0 in

Fy= 55,000 psi

$$\begin{aligned} C &= P_1 + P_2 + P_3 \quad t_{clip} = 0.18 \text{ in} \\ &= P_1 + P_1 * (2.5" / 4.5") + P_1 * (0.5" / 4.5") \\ &= 1.667 * P_1 \end{aligned}$$

$$S_{clip} = 0.127 \text{ in}^3$$

$$\begin{aligned} M_{cap} &= S_{clip} * F_{bending} \\ &= 0.127 \text{ in}^3 * 0.66 * F_y \\ &= 4,610 \text{ in-lb} \end{aligned}$$

$$C * d = M_{cap} = 1.667$$

$$\begin{aligned} d &= E / 2 \\ &= 0.50 \text{ in} \end{aligned}$$

$$\begin{aligned} P_{clip} &= M_{cap} / (1.667 * d) \\ &= 4610.1 \text{ in-lb} / (1.667 * 0.5 \text{ in}) \\ &= 5,531 \text{ lb} \end{aligned}$$

Thus, P1= 2,562 lb

$$\begin{aligned} M_{conn-allow} &= [P_1 * 4.5" + P_1 * (2.5" / 4.5") * 2.5" + P_1 * (0.5" / 4.5") * 0.5"] \\ &= 2562 \text{ LB} * [4.5" + (2.5" / 4.5") * 2.5" + (0.5" / 4.5") * 0.5"] \\ &= 15,230 \text{ in-lb} > M_{conn \max}, \text{ OK} \end{aligned}$$

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: **Johnson Storage**

Project #: **24-1119**

Transverse Brace

Configuration: TYPE A SELECTIVE RACK

12

Section Properties

Diagonal Member= Intlk 1-1/2x1-1/2x14ga


Area= 0.315 in²

r min= 0.488 in

Fy= 55,000 psi

K= 1.0

Ωc= 1.92




Horizontal Member= Intlk 1-1/2x1-1/2x14ga

Area= 0.315 in²

r min= 0.488 in

Fy= 55,000 psi

K= 1.0



Frame Dimensions

Bottom Panel Height=H= 73.0 in

Frame Depth=D= 42.0 in

Column Width=B= 3.0 in

Clear Depth=D-B*2= 36.0 in

X Brace= NO

rho= 1.00

Diagonal Member

Load Case 6: $(1+0.104*Sds)D + [(0.85+0.14Sds)*B*P + [0.7*\rho*E]] \leq 1.0$, ASD Method

Vtransverse= 364 lb

Vb=Vtransv*0.7*rho= 364 lb * 0.7 * 1

= 255 lb

Ldiag= $[(D-B*2)^2 + (H-6'')^2]^{1/2}$

= 76.1 in

Pmax= V*(Ldiag/D) * 0.75

= 346 lb

axial load on diagonal brace member

Pn= AREA*Fn

= 0.315 in² * 11979 psi

= 3,773 lb

Pallow= Pn/Ω

= 3773 lb /1.92

= 1,965 lb

Pn/Pallow= 0.18 <= 1.0 OK

$(kl/r) = (k * Ldiag)/r \text{ min}$
= (1 x 76.1 in /0.488 in)

= 155.9 in


$Fe = \pi^2 * E / (kl/r)^2$

= 11,979 psi

Since $Fe < Fy/2$,

Fn= Fe

= 11,979 psi



Check End Weld

Lweld= 3.0 in

Fu= 65 ksi

tmin= 0.075 in

Weld Capacity= 0.75 * tmin * L * Fu/2.5

= 4,388 lb OK

Horizontal brace

Vb=Vtransv*0.7*rho= 255 lb

$(kl/r) = (k * Lhoriz)/r \text{ min}$

= (1 x 42 in) /0.488 in

= 86.1 in

Since $Fe > Fy/2$, $Fn = Fy * (1 - fy/4fe)$

= 35,745 psi

$Fe = \pi^2 * E / (kl/r)^2$

= 39,275 psi

$Fy/2 = 27,500 \text{ psi}$

Pn= AREA*Fn

= 0.315 in² * 35745 psi

= 11,260 lb

Pallow= Pn/Ωc

= 11260 lb /1.92

= 5,864 lb

Pn/Pallow= 0.04 <= 1.0 OK

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S Project: **Johnson Storage** Project #: **24-1119**
Single Row Frame Overturning Configuration: TYPE A SELECTIVE RACK
Loads 12

Critical Load case(s):


1) RMI Sec 2.2, item 7: $(0.9-0.2Sds)D + (0.9-0.20Sds)*B*Papp - E*rho$

$V_{trans}=V=E=Q_e= 364 \text{ lb}$
DEAD LOAD PER UPRIGHT= $D= 375 \text{ lb}$
PRODUCT LOAD PER UPRIGHT= $P= 20,000 \text{ lb}$
 $Papp=P*0.67= 13,400 \text{ lb}$
 $Wst \text{ LC1}=Wst1=(0.87888*D + 0.87888*Papp*1)= 12,106 \text{ lb}$

Product Load Top Level, $P_{top}= 4,000 \text{ lb}$
 $DL/Lvl= 75 \text{ lb}$
Seismic Ovt based on E, $\Sigma(F_i*hi)= 65,749 \text{ in-lb}$
height/depth ratio= 7.9 in

$Sds= 0.1056$
 $(0.9-0.2Sds)= 0.8789$
 $(0.9-0.2Sds)= 0.8789$
 $B= 1.0000$
 $\rho= 1.0000$

Frame Depth= $D_f= 42.0 \text{ in}$
 $H_{top-lvl}=H= 330.0 \text{ in}$
Levels= 5
Anchors/Base= 2
 $hp= 48.0 \text{ in}$



SIDE ELEVATION

A) Fully Loaded Rack

$h=H+hp/2= 354.0 \text{ in}$

Load case 1:

$Movt= \Sigma(F_i*hi)*E*rho$
 $= 65,749 \text{ in-lb}$

$Mst= Wst1 * D_f/2$
 $= 12106 \text{ lb} * 42 \text{ in}/2$
 $= 254,226 \text{ in-lb}$

$T= (Movt-Mst)/D_f$
 $= (65749 \text{ in-lb} - 254226 \text{ in-lb})/42 \text{ in}$
 $= -4,488 \text{ lb}$ **No Uplift**

Net Seismic Uplift= -4,488 lb

B) Top Level Loaded Only

Load case 1:

$V1=V_{top}= Cs * I_p * P_{top} \geq 350 \text{ lb for } H/D > 6.0$
 $= 0.0264 * 4000 \text{ lb}$
 $= 106 \text{ lb}$

$V1_{eff}= 350 \text{ lb}$

$V2=V_{DL}= Cs*I_p*D$
 $= 10 \text{ lb}$

$Mst= (0.87888*D + 0.87888*P_{top}*1) * 42 \text{ in}/2$
 $= 80,747 \text{ in-lb}$

Critical Level= 5

$Cs*I_p= 0.0264$

$Movt= [V1*h + V2 * H/2]*rho$
 $= 125,534 \text{ in-lb}$

$T= (Movt-Mst)/D_f$
 $= (125534 \text{ in-lb} - 80747 \text{ in-lb})/42 \text{ in}$
 $= 1,066 \text{ lb}$ **Net Uplift per Column**

Net Seismic Uplift= 1,066 lb

Anchor

Check (2) 0.5" x 3.25" Embed POWERS SD1 anchor(s) per base plate.

Special inspection is not required per ESR 2818.

Pullout Capacity= $T_{cap}= 970 \text{ lb}$

Shear Capacity= $V_{cap}= 1,250 \text{ lb}$

L.A. City Jurisdiction? NO

$\Phi= 1$

$T_{cap}*\Phi= 970 \text{ lb}$

$V_{cap}*\Phi= 1,250 \text{ lb}$

Fully Loaded:

$(91 \text{ lb}/1250 \text{ lb})^1 = 0.07$

$\leq 1.2 \text{ OK}$

Top Level Loaded:

$(533 \text{ lb}/970 \text{ lb})^1 + (87 \text{ lb}/1250 \text{ lb})^1 = 0.62$

$\leq 1.2 \text{ OK}$

Structural Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S

Project: **Johnson Storage**

Project #: **24-1119**

Base Plate

Configuration: TYPE A SELECTIVE RACK

12

Section

Baseplate= 7.75x5x0.375

Eff Width=W = 7.75 in

Eff Depth=D = 5.00 in

Column Width=b = 3.00 in

Column Depth=dc = 3.00 in

L = 2.38 in


Plate Thickness=t = 0.375 in

a = 2.88 in

Anchor c.c. = 2*a = d = 5.75 in

N=# Anchor/Base= 2

Fy = 36,000 psi



Downaisle Elevation

Down Aisle Loads Load Case 5: : $(1+0.105*Sds)D + 0.75*[(1.4+0.14Sds)*B*P + 0.75*[0.7*\rho*E]] \leq 1.0$, ASD Method

COLUMN DL= 188 lb

COLUMN PL= 10,000 lb

Base Moment= 0 in-lb

1+0.105*Sds= 1.0111

1.4+0.14Sds= 1.4148

B= 0.7000

Axial=P= $1.011088 * 187.5 \text{ lb} + 0.75 * (1.414784 * 0.7 * 10000 \text{ lb})$
= **7,617 lb**

Mb= Base Moment*0.75*0.7*rho

= 0 in-lb * 0.75*0.7*rho

= 0 in-lb

Axial Load P = 7,617 lb

Mbase=Mb = 0 in-lb

Axial stress=fa = P/A = P/(D*W)

= 197 psi

M1= $wL^2/2 = fa*L^2/2$

= 554 in-lb

Moment Stress=fb = M/S = 6*Mb/[(D*B^2)]

= 0.0 psi

Moment Stress=fb2 = 2 * fb * L/W

= 0.0 psi

Moment Stress=fb1 = fb-fb2

= 0.0 psi

M2= $fb1*L^2/2$

= 0 in-lb

M3 = $(1/2)*fb2*L*(2/3)*L = (1/3)*fb2*L^2$

= 0 in-lb

Mtotal = M1+M2+M3

= 554 in-lb/in

S-plate = $(1)*(t^2)/6$

= 0.023 in^3/in

Fb = 0.75*Fy

= 27,000 psi

fb/Fb = Mtotal/[(S-plate)(Fb)]

= **0.88**

OK

F'p = 0.7*F'c

= 2,800 psi

OK

Tanchor = $(Mb-(PLapp*0.75*0.46)(a))/[(d)*N/2]$

= -6,053 lb

No Tension

Tallow= 970 lb

OK

Cross Aisle Loads Critical load case RMI Sec 2.1, Item 4: $(1+0.11Sds)DL + (1+0.14Sds)PL*0.75+EL*0.75 \leq 1.0$, ASD Method

Check uplift load on Baseplate

Pstatic= 7,617 lb

Movt*0.75*0.7*rho= 34,518 in-lb

Frame Depth= 42.0 in

Pseismic= Movt/Frame Depth

= 822 lb

P=Pstatic+Pseismic= 8,439 lb

b = Column Depth= 3.00 in

L = Base Plate Depth-Col Depth= 2.38 in

fa = P/A = P/(D*W)

= 218 psi

M= $wL^2/2 = fa*L^2/2$

= 614 in-lb/in

Sbase/in = $(1)*(t^2)/6$

= 0.023 in^3/in

Fbase = 0.75*Fy

= 27,000 psi


fb/Fb = M/[(S-plate)(Fb)]

= **0.97**

OK

Check uplift forces on baseplate with 2 or more anchors per RMI 7.2.2.

"When the base plate configuration consists of two anchor bolts located on either side of the column and a net uplift force exists, the minimum base plate thickness shall be determined based on a design bending moment in the plate equal to the uplift force on one anchor times 1/2 the distance from the centerline of the anchor to the nearest edge of the rack column"



Elevation

Uplift per Column= 1,066 lb

Qty Anchor per BP= 2

Net Tension per anchor=Ta= 533 lb

c= 2.38 in

Mu= Moment on Baseplate due to uplift= Ta*c/2

= 633 in-lb

Splate= 0.117 in^3

[fb/Fb]*0.75= 0.15

OK

Structural Engineering & Design Inc.

1815 Wright Ave. La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186

By: Dray S


Project: **Johnson Storage**

Project #: **24-1119**


Slab on Grade

Configuration: TYPE A SELECTIVE RACK

12



SLAB ELEVATION



Baseplate Plan View

Base Plate

Effec. Baseplate width=B= 7.75 in

Effec. Baseplate Depth=D= 5.00 in

width=a= 3.00 in

depth=b= 3.00 in

midway dist face of column to edge of plate=c= 5.38 in

midway dist face of column to edge of plate=e= 4.00 in

Column Loads

DEAD LOAD=D= 188 lb per column

unfactored ASD load

PRODUCT LOAD=P= 10,000 lb per column

unfactored ASD load

Papp= 6,700 lb per column

P-seismic=E= (Movt/Frame depth)

= 1,565 lb per column

unfactored Limit State load

B= 0.7000

rho= 1.0000

Sds= 0.1056

1.2 + 0.2*Sds= 1.2211

0.9 - 0.20Sds= 0.8789

Load Case 1) $(1.2+0.2Sds)D + (1.2+0.2Sds)*B*P + \rho*E$ RMI SEC 2.2 EQTN 5

= $1.22112 * 188 \text{ lb} + 1.22112 * 0.7 * 10000 \text{ lb} + 1 * 1565 \text{ lb}$

= 10,342 lb

Load Case 2) $(0.9-0.2Sds)D + (0.9-0.2Sds)*B*P + \rho*E$ RMI SEC 2.2 EQTN 7

= $0.87888 * 188 \text{ lb} + 0.87888 * 0.7 * 6700 \text{ lb} + 1 * 1565 \text{ lb}$

= 5,852 lb

Load Case 3) $1.2*D + 1.4*P$ RMI SEC 2.2 EQTN 1,2

= $1.2*188 \text{ lb} + 1.4*10000 \text{ lb}$

= 14,225 lb

Load Case 4) $1.2*D + 1.0*P + 1.0E$ ACI 318-14 Sec 5.3.1

= 11,791 lb

Eqtn 5.3.1e

Effective Column Load=Pu= 14,225 lb per column

Puncture

$A_{punct} = [(c+t)+(e+t)]*2*t$

= 256.50 in²

$F_{punct1} = [(4/3 + 8/(3*\beta))] * \lambda * (F'c^{0.5})$

= 115.8 psi

$F_{punct2} = 2.66 * \lambda * (F'c^{0.5})$

= 100.9 psi

$F_{punct \text{ eff}} = 100.9 \text{ psi}$

$f_v/F_v = P_u/(A_{punct}*F_{punct})$

= **0.550 < 1 OK**

Slab Bending

$P_{se} = DL + PL + E = 14,225 \text{ lb}$

$A_{soil} = (P_{se}*144)/(f_{soil})$

= 2,731 in²

$x = (L-y)/2$

= 17.8 in

$F_b = 5*(\phi)*(f'c)^{0.5}$

= 189.74 psi

$L = (A_{soil})^{0.5}$

= 52.26 in

$M = w*x^2/2$

= $(f_{soil}*x^2)/(144*2)$

= 826.1 in-lb

$y = (c*e)^{0.5} + 2*t$

= 16.6 in

$S_{\text{-slab}} = 1*t_{eff}^2/6$

= 6.0 in³

$f_b/F_b = M/(S_{\text{-slab}}*F_b)$

= **0.726 < 1, OK**

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186


By: Dray S

Project: **Johnson Storage**

Project #: **24-1119**

Configuration & Summary: TYPE B SELECTIVE RACK

12



**RACK COLUMN REACTIONS

ASD LOADS

AXIAL DL= 188 lb

AXIAL LL= 10,000 lb

SEISMIC AXIAL Ps= +/- 1,608 lb

BASE MOMENT= 0 in-lb

Seismic Criteria	# Bm Lvl	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=0.099, Fa=1.6	5	42 in	348.0 in	6	140 in	

Component		Description							STRESS	
Column		Fy=55 ksi	INTLK LU75/3x3x13ga			P=10188 lb, M=14788 in-lb			0.96-OK	
Column & Backer		None	None			None			N/A	
Beam		Fy=55 ksi	Intlk 50E 5Hx2.75Wx0.059"Thk			Lu=140 in	Capacity: 4309 lb/pr		0.93-OK	
Beam Connector		Fy=55 ksi	Lvl 1: 3 pin OK		Mconn=10373 in-lb		Mcap=15230 in-lb		0.68-OK	
Brace-Horizontal		Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga							0.04-OK
Brace-Diagonal		Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga							0.18-OK
Base Plate		Fy=36 ksi	7.75x5x0.375				Fixity= 0 in-lb		0.97-OK	
Anchor		2 per Base	0.5" x 3.25" Embed POWERS SD1 ESR 2818 No Inspection (Net Seismic Uplift=1150 lb)							0.55-OK
Slab & Soil		6" thk x 4000 psi slab on grade. 750 psf Soil Bearing Pressure							0.46-OK	
Level	Load** Per Level	Beam Spcg	Brace	Story Force Transv	Story Force Longit.	Column Axial	Column Moment	Conn. Moment	Beam Connector	
1	4,000 lb	68.0 in	52.0 in	24 lb	30 lb	10,188 lb	14,788 "#	10,373 "#	3 pin OK	
2	4,000 lb	68.0 in	52.0 in	49 lb	61 lb	8,150 lb	7,220 "#	7,363 "#	3 pin OK	
3	4,000 lb	68.0 in	73.0 in	73 lb	91 lb	6,113 lb	6,188 "#	6,461 "#	3 pin OK	
4	4,000 lb	68.0 in	73.0 in	97 lb	121 lb	4,075 lb	4,641 "#	5,197 "#	3 pin OK	
5	4,000 lb	68.0 in	73.0 in 12.0 in	121 lb	152 lb	2,038 lb	2,579 "#	3,573 "#	3 pin OK	

** Load defined as product weight per pair of beams

Total: 364 lb 455 lb

Notes Std row spacers

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186


By: Dray S

Project: Johnson Storage

Project #: 24-1119

Configuration & Summary: TYPE C SELECTIVE RACK

12



**RACK COLUMN REACTIONS

ASD LOADS

AXIAL DL= 188 lb

AXIAL LL= 10,000 lb

SEISMIC AXIAL Ps= +/- 1,407 lb

BASE MOMENT= 0 in-lb

Seismic Criteria	# Bm Lvl	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=0.099, Fa=1.6	5	48 in	348.0 in	6	140 in	Single Row

Component		Description							STRESS	
Column		Fy=55 ksi	INTLK LU75/3x3x13ga			P=10188 lb, M=14788 in-lb			0.96-OK	
Column & Backer		None	None			None			N/A	
Beam		Fy=55 ksi	Intlk 50E 5Hx2.75Wx0.059"Thk			Lu=140 in	Capacity: 4309 lb/pr		0.93-OK	
Beam Connector		Fy=55 ksi	Lvl 1: 3 pin OK	Mconn=10373 in-lb			Mcap=15230 in-lb		0.68-OK	
Brace-Horizontal		Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga							0.05-OK
Brace-Diagonal		Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga							0.17-OK
Base Plate		Fy=36 ksi	7.75x5x0.375				Fixity= 0 in-lb		0.96-OK	
Anchor		2 per Base	0.5" x 3.25" Embed POWERS SD1 ESR 2818 No Inspection (Net Seismic Uplift=766 lb)							0.383-OK
Slab & Soil		6" thk x 4000 psi slab on grade. 750 psf Soil Bearing Pressure							0.43-OK	
Level	Load** Per Level	Beam Spcg	Brace	Story Force Transv	Story Force Longit.	Column Axial	Column Moment	Conn. Moment	Beam Connector	
1	4,000 lb	68.0 in	52.0 in	24 lb	30 lb	10,188 lb	14,788 "#	10,373 "#	3 pin OK	
2	4,000 lb	68.0 in	52.0 in	49 lb	61 lb	8,150 lb	7,220 "#	7,363 "#	3 pin OK	
3	4,000 lb	68.0 in	73.0 in	73 lb	91 lb	6,113 lb	6,188 "#	6,461 "#	3 pin OK	
4	4,000 lb	68.0 in	73.0 in	97 lb	121 lb	4,075 lb	4,641 "#	5,197 "#	3 pin OK	
5	4,000 lb	68.0 in	73.0 in	121 lb	152 lb	2,038 lb	2,579 "#	3,573 "#	3 pin OK	

** Load defined as product weight per pair of beams

Total: 364 lb 455 lb

Notes

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186


By: Dray S

Project: Johnson Storage

Project #: 24-1119

Configuration & Summary: TYPE D SELECTIVE RACK

12



**RACK COLUMN REACTIONS

ASD LOADS

AXIAL DL= 188 lb

AXIAL LL= 10,000 lb

SEISMIC AXIAL Ps= +/- 1,407 lb

BASE MOMENT= 0 in-lb

Seismic Criteria	# Bm Lvl	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=0.099, Fa=1.6	5	48 in	348.0 in	6	144 in	Single Row

Component		Description						STRESS	
Column	Fy=55 ksi	INTLK LU75/3x3x13ga			P=10188 lb, M=14788 in-lb			0.96-OK	
Column & Backer	None	None			None			N/A	
Beam	Fy=55 ksi	Intlk 50E 5Hx2.75Wx0.059"Thk			Lu=144 in	Capacity: 4097 lb/pr		0.98-OK	
Beam Connector	Fy=55 ksi	Lvl 1: 3 pin OK		Mconn=10550 in-lb		Mcap=15230 in-lb		0.69-OK	
Brace-Horizontal	Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga						0.05-OK	
Brace-Diagonal	Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga						0.17-OK	
Base Plate	Fy=36 ksi	7.75x5x0.375				Fixity= 0 in-lb		0.96-OK	
Anchor	2 per Base	0.5" x 3.25" Embed POWERS SD1 ESR 2818 No Inspection (Net Seismic Uplift=766 lb)						0.383-OK	
Slab & Soil		6" thk x 4000 psi slab on grade. 750 psf Soil Bearing Pressure						0.43-OK	
Level	Load** Per Level	Beam Spcg	Brace	Story Force Transv	Story Force Longit.	Column Axial	Column Moment	Conn. Moment	Beam Connector
1	4,000 lb	68.0 in	52.0 in	24 lb	30 lb	10,188 lb	14,788 "#	10,550 "#	3 pin OK
2	4,000 lb	68.0 in	52.0 in	49 lb	61 lb	8,150 lb	7,220 "#	7,540 "#	3 pin OK
3	4,000 lb	68.0 in	73.0 in	73 lb	91 lb	6,113 lb	6,188 "#	6,638 "#	3 pin OK
4	4,000 lb	68.0 in	73.0 in	97 lb	121 lb	4,075 lb	4,641 "#	5,375 "#	3 pin OK
5	4,000 lb	68.0 in	73.0 in	121 lb	152 lb	2,038 lb	2,579 "#	3,750 "#	3 pin OK
			12.0 in						

** Load defined as product weight per pair of beams

Total: 364 lb 455 lb

Notes

Structural Engineering & Design Inc.

1815 Wright Ave La Verne, CA 91750 Tel: 909.596.1351 Fax: 909.596.7186


By: Dray S

Project: **Johnson Storage**

Project #: **24-1119**

Configuration & Summary: TYPE T INTERIOR SELECTIVE RACK

12



**RACK COLUMN REACTIONS

ASD LOADS

AXIAL DL = 188 lb

AXIAL LL = 8,000 lb

SEISMIC AXIAL Ps = +/- 1,328 lb

BASE MOMENT = 0 in-lb

Seismic Criteria	# Bm Lvl	Frame Depth	Frame Height	# Diagonals	Beam Length	Frame Type
Ss=0.099, Fa=1.6	3	42 in	348.0 in	6	144 in	Single Row

Component		Description						STRESS	
Column		Fy=55 ksi	INTLK LU75/3x3x13ga			P=8188 lb, M=11529 in-lb			0.69-OK
Column & Backer		None	None			None			N/A
Beam		Fy=55 ksi	Intlk 50E 5Hx2.75Wx0.059"Thk			Lu=144 in	Capacity: 4097 lb/pr		0.98-OK
Beam Connector		Fy=55 ksi	Lvl 3: 3 pin OK		Mconn=6125 in-lb		Mcap=15230 in-lb		0.4-OK
Brace-Horizontal		Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga						0.03-OK
Brace-Diagonal		Fy=55 ksi	Intlk 1-1/2x1-1/2x14ga						0.14-OK
Base Plate		Fy=36 ksi	7.75x5x0.375				Fixity= 0 in-lb		0.79-OK
Anchor		2 per Base	0.5" x 3.25" Embed POWERS SD1 ESR 2818 No Inspection (Net Seismic Uplift=1066 lb)						0.517-OK
Slab & Soil		6" thk x 4000 psi slab on grade. 750 psf Soil Bearing Pressure							0.36-OK
Level	Load** Per Level	Beam Spcg	Brace	Story Force Transv	Story Force Longit.	Column Axial	Column Moment	Conn. Moment	Beam Connector

3	4,000 lb	66.0 in	73.0 in	65 lb	81 lb	6,113 lb	5,351 "	6,125 "	3 pin OK
4	4,000 lb	66.0 in	73.0 in	87 lb	108 lb	4,075 lb	4,013 "	5,032 "	3 pin OK
5	4,000 lb	66.0 in	73.0 in	108 lb	135 lb	2,038 lb	2,229 "	3,628 "	3 pin OK
			12.0 in						

** Load defined as product weight per pair of beams

Total: 293 lb 366 lb

Notes

Interior tunnel