

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20242691  
**Address:** 1621 SW ARBORWAY TER, LEES SUMMIT, MO 64082  
**Inspected On:** Monday, November 25, 2024  
**Inspected By:** Development Center  
**Expiration Date:** 12/26/2024 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Ready for Temp CO	Monday, November 25, 2024

**Corrective Action Required:**

2	Miscellaneous Correction	- Driveway final inspection needs to be completed - Sod, splash pads and sump pump extension needs to be installed
---	--------------------------	---

Passed for TCO only

**Comments:**