

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242945
Address: 3718 SW KNOXVILLE CT, LEES SUMMIT, MO 640823716 SW KNOXVILLE CT, LEES SUMMIT, MO
64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Not Ready	Monday, November 25, 2024

Corrective Action Required:

1	Miscellaneous Correction	3718 Better seal electrical service cable and bonding wire at demising wall (Firewall/Rated assembly wall)
---	-----------------------------	--

-No improvements made from last inspection
-Not ready
11/25/2024. KBEARD

Comments: