

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235113

Address: 2740 NE HAGAN RD, Unit:A, LEES SUMMIT, MO 640642740 NE HAGAN RD, Unit:B, LEES SUMMIT,  
MO 640642740 NE HAGAN RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Khanh Nguyen	Partial	Monday, November 25, 2024

Informational:

1 Misc

Footing OK to pour, pending approval from on-site special inspector:

- Elevator pad and foundation wall
- Exterior wall footing
- Interior grade beam: Line 1.3 to 8 from M to C
- Restroom/storm shelter
- Trash enclosure
- Footing at trench drains

**Comments:**