

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20240452
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface	Bobby Richest	Partial	Thursday, October 24, 2024

Informational:
1 Misc

10-24-24 BR Contractor (ESS) poured concrete for lane widening section on SE Bailey Rd. on both ends of turning lane.

11-25-24 BR Contractor installed reminder 5" of KCMMB A-3 asphalt base on SE Bailey Rd. with 3rd party inspector (Ideker Inc.) getting 94 - 96 compaction.

Comments: