



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113810, Building Permit - Commercial
Address: 117 SE M 291 HWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	Mark Harding	Failed	Thursday, November 03, 2011

Partial Correction
1 MISC

HOOD INSPECTED AND APPROVED WELDS ON THE GROUND.
WILL INSPECT WHEN FINAL INSTALL COMPLETE.
11-3-11- CLEAN WELDS AND WIRE LEFT ON WELDING .
LOWER TRAY SECTION OF CENTER HOOD IS 1" LOWER THAN
HORIZONTAL ARMS.
HORIZONTAL ARMS -PROVIDE APPROVED FALL.

Comments: