



## **FIRE DEPARTMENT**

**Prevention Division  
(816)969-1300**

### **PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20241150	Date:	November 26, 2024
Project Title:	TOTAL BODY FITNESS INFRARED SAUNA INSTALL	Applicant:	
Location:	3680 NE AKIN DR, Unit:122, LEES SUMMIT, MO 64064	SQUARE FOOT CONSTRUCTION	1001 SW CROSSING DR LEES SUMMIT, MO 64081
Type of Work:		Primary:	(816) 716-7527
Occupancy Group:	A-4		
Description:	TOTAL BODY FITNESS - REPLACE SHOWER ROOM WITH SAUNA		
Construction Type:	Type IIB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Craig Hill**

**Rejected**

1. No sprinkler plans were found to be uploaded to the system.

Provide a single sprinkler head in the sauna. Plans are not required if the sauna is the only construction/modification being made to the space. A letter of acknowledgment will suffice.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**