

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242933
Address: 2218 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Robb Popp	Failed	Tuesday, November 26, 2024

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	11/21/24 DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. -Maintain silt fence -Remove trash and debris from street and storm inlet
---	---------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	DCM5 ESC INSP DENIED	11/26/24 REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION.
---	-------------------------	----------------------------------------------------------------------------------------------

Comments: