

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245318
Address: 2750 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Devon Perry	Failed	Tuesday, November 26, 2024

Corrective Action Required:

1	Misc	Erosion control in compliance
---	------	-------------------------------

Corrective Action Required:

2	Miscellaneous Correction	11-26-24 DP. Silt fence and waddles installed are in working order and appreciated. We need to add a gutter buddy at the storm inlet in front of this property, ASAP. We have rain coming tomorrow. Also, the concrete wash outs are over flowing and need replaced with fresh wash out areas. If you need further info on details for installing a gutter buddy please reach out to 816-969-1219. Thanks.
---	-----------------------------	--

Comments: