

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242156  
Address: 2760 SW 11TH ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Robb Popp	Failed	Tuesday, November 26, 2024

Corrective Action Required:

1	Misc	-CSST at fireplace has no appliance or shut off -Remove unused CSST - CSST at oven should land below floor- No change -All CSST secured within 3" of top or bottom of joist space requires 16g striker plates
---	------	---

**Comments:**