

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245422
Address: 3207 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Mark Harding	Failed	Tuesday, November 26, 2024

Corrective Action Required:

1	Misc	interior drain tile not complete, cut in multiple places, not connected to sump pit.
		Plmb- connect shower drain down stream of toilet and shower.
		complete erosion and gravel filter at street.

Comments: