

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242079
Address: 1604 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Mark Harding	Failed	Wednesday, November 27, 2024

Corrective Action Required:

1	Misc	No gas line installed
---	------	-----------------------

**Install pressure gauge with range no more than 30 psi.

Corrective Action Required:

2	Misc	denied
---	------	--------

Comments: