

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240569
Address: 2755 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Wednesday, November 27, 2024

Corrective Action Required:

- | | | |
|---|--------------------------|---|
| 1 | Miscellaneous Correction | -Permanent address numbers are not installed
-Garage to house self closing door does not fully shut and lock
-Fire block all gaps in the sheet rock in garage above overhead garage doors
-One deck joist hanger is missing nails
Irrigation permit needs to be obtained
-Sod, splash pads and sump pump extension are not installed |
|---|--------------------------|---|

Comments: