

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242187  
Address: 1613 SW ARBORWAY TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Kyle Beard	Failed	Wednesday, November 27, 2024

Corrective Action Required:

2	Miscellaneous Correction	Seal gaps under chase in garage Garage to house steps need guard rail and handrail installed One garage electrical receptacle needs to be GFCI protected Install anti hammer device at kitchen sink Hood vent is not installed Sod, splash pads and sump pump extension is not installed Driveway final is not completed Plot plan needs to pass Pay \$75 fee associated with this permit
---	-----------------------------	---

Comments: