

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234052
Address: 150 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Robb Popp	Failed	Monday, December 02, 2024

Informational:

1 Misc

Inspection is for 800 amp disconnect and 100 amp HP only:

- Provide 2/0 GEC to building steel and metallic water line
- CEE is not permitted to be spliced
- Update plans to show use of 500 MCM conductors instead of 250 MCM per plan

Comments: