



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20114738, Building Permit - Commercial  
Address: 1702 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Plumbing Inspection - Commercial</b>	John Borns	Partial	Friday, November 04, 2011

Partial Correction  
1 MISC

OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY  
BUILDING DRAIN UNDER SPACES 116, 115, 114, 113, 112, & 111  
AND LATERALS WEST THEREOF ACROSS CORRIDOR 122;

**Comments:**