

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242194
Address: 2111 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, December 02, 2024

Corrective Action Required:

1	Misc	-provide as graded plot plan -identify sewer tracer wire -label all circuit breakers -afci protection for all kitchen circuits (see kitchen refrigerator) -gfcı protection for outlets under kitchen sink
---	------	---

Comments: