

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241135
Address: 3249 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, December 02, 2024

Corrective Action Required:

1	Misc	PERMIT IN NOV STATUS. PLEASE ADDRESS ALL ITEMS AND COMPLETE
---	------	---

- pay all fees
- sod
- splash blocks and sump pump discharge to extend 36" from foundation
- bring water meter well to grade (ensure 14"-18" from top of meter to well lid ring)
- bring valves tops to grade

Comments: