

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241184  
Address: 3208 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Monday, December 02, 2024

Corrective Action Required:

1	Misc	TCO EXPIRED PERMIT IN NOV STATUS pay all fees  -splash blocks and sump pump discharge to extend 36" from foundation -missing egress ladder for window well -will check water meter at time of sod (ensure meter well lid flush with grade and meter 14"-18" from top of meter to well lid ring) -address plot plan not matching as built
---	------	---

Comments: