

1138 Kansas Avenue
Kansas City, KS 66105
P 913-371-8494
F 913-321-3457

Craig.Schraad@KellerFire.com



KellerFire.com

System Integrators: ■ Fire Alarm ■ Clean Agent Suppression ■ Access Control ■ Fire Extinguishers ■ Kitchen Hood Suppression ■ 24 Hr Service

Date: 12/02/2024
To: Lee's Summit Fire Prevention Division – Craig Hill & Jim Eden
RE: Plans Review Conditions – PRCOM20241150
Subject: Total Body Fitness – Fire Alarm and Sprinkler

To whom it may concern,

Keller Fire & Safety shall provide the following work for Total Body Fitness – Sauna Room Conversion located at 3680 N.E. Akin Drive, Suite 122, Lee's Summit, MO 64064.

1. Provide a new sprinkler head in the waiting area outside of Sauna.
2. Relocate existing sprinkler head in Sauna.
3. Relocate existing horn/strobe outside and directly across from Sauna; which has a glass wall allowing strobe to cover both the hall and Sauna.

Best Regards,

Aaron J. Smith
Engineered Systems Designer
Keller Fire & Safety
1138 Kansas Avenue
Kansas City, KS 66105
Aaron.Smith@Kellerfire.com
P: 913.371.8494
F: 913.321.3457