

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20234175  
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Miscellaneous Inspection</b>	Shawn Hoffman	Failed	Monday, December 02, 2024

Corrective Action Required:

1	Misc	Called Steve Skinner 816-225-2517 no answer, left message. No footing inspection done or third party report submitted. all rough deficiencies: portal frame straps, electrical panel labels. no one on location when I went by. Shawn Hoffman 10/03/2024 3:06 PM
---	------	--

Corrective Action Required:

2	Misc	Shawn Hoffman 11/19/2024 3:12 PM - received footing third party report that failed. - pictures of straps
---	------	--

Informational:

3	Misc	- New footing letter accepted  - need to schedule inspection for me to look at straps and electrical.
---	------	---

Comments: