

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234924
Address: 2782 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Monday, December 02, 2024

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- Final grading and sod- Provide splash pads , divert water 36" away from foundation- sump discharge to be 36" away from foundation
---	------	---

Comments: