

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20231351
Address: 2840 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 2	Bobby Richest	Failed	Tuesday, November 12, 2024

Informational:

1	Misc	11-7-24 BR Contractor 2nd sample on water line A, line G, line B, & line C coliform test.
		11-12-24 BR 2nd sample came back with 2 out of 3 samples has pass. 1 sample spot needs the taking again do to not passing.
		12-2-24 BR 3rd sample on water line A, line G, line B, & line C has pass.

Comments: