

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241253  
Address: 3125 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:       | Outcome: | Date:                      |
|-------------------------------------------------|------------------|----------|----------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Mitchell Schwarz | Failed   | Tuesday, December 03, 2024 |

Corrective Action Required:

|   |      |             |
|---|------|-------------|
| 1 | Misc | TCO EXPIRED |
|---|------|-------------|

- Address pending sidewalk inspection
- Address to be properly illuminated
- water meter well lid to be brought to grade. Ensure 14"-18" from top of meter to well lid ring

**Comments:**