CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20230570

Address: 1950 SE BLUE PKWY, LEES SUMMIT, MO 64063

Inspected On: Tuesday, December 03, 2024

Inspected By: Khanh Nguyen

Expiration Date: 12/14/2024 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Ready for Temp CO Thursday, November 14, 2024

Commercial

Corrective Action Required:

1 Misc -Approval required from: Fire, Planning, FEI

-Provide compliance with NEC 110.16(B)

-Provide gfi protection for receptacles located within 6 ft of nourishment area

sink

-Provide a clear floor space with minimum 30" width at urinal. Min. distance

from centerline of urinal to wall shall be 15". Have architect address. -All receptacles less than 5.5 ft from floor located in business offices and corridors of medical facility are required to be tamper-resistant receptacles.

NEC 496.12 (5)

-Provide verification of 1-hr fire rating of the roof access rm wall

-Secure rooftop unit LFNC raceways per code

Occupancy Inspection - Codes Khanh Nguyen Ready for Temp CO Friday, October 18, Commercial 2024

Corrective Action Required:

-Approval required from: Fire, Planning, FEI Misc

-Provide compliance with NEC 110.16(B)

- -Provide gfi protection for receptacles located within 6 ft of nourishment area sink
- -Provide a clear floor space with minimum 30" width at urinal. Have architect address
- -All receptacles less than 5.5 ft from floor located in business offices and corridors of medical facility are required to be tamper-resistant receptacles. NEC 496.12 (5)
- -Provide verification of 1-hr fire rating of the roof access rm wall
- -Secure rooftop unit LFNC raceways per code

Comments: