

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242566
Address: 3117 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Failed	Tuesday, December 03, 2024

Informational:
1 Misc 11-26-24 Dustin A, SW has been formed and compacted. Slopes are in compliance. Approved to pour
12-2-24 Dustin A, Sw is poured and slopes are in compliance. Expansion joint was forgot at approach . Fail Talked with Forrest and he is aware. Will need a pre pour on panel once removed to correct.

Comments: