

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20230994  
Address: 1021 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Robb Popp	Partial	Tuesday, December 03, 2024

Corrective Action Required:

1	Misc	-UE to junction near trash enclosure - UE to light pole at South West corner - UE to light pole West side - UE to monument sign South West corner - UE to hamblen rd. for phone and future power -UE from NE corner for compressor and vac at NW and HD sign, -UE from NE corner north to car chargers and light pole at north drive -UE stubbed out from (4) light pole bases at north, northeast, south and southwest -UE at NE drive for future
---	------	--

Comments: