

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20241253
Address: 3125 SW ARBORIDGE DR, LEES SUMMIT, MO 64082
Inspected On: Tuesday, December 03, 2024
Inspected By: Development Center
Expiration Date: 10/20/2024 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Friday, September 20, 2024
Corrective Action Required: 2 Misc	-Address pending sidewalk inspection -as graded plot plan required -sod -splash blocks and sump pump discharge to extend 36" from foundation -Address to be properly illuminated -uncover covered water meter		

Comments: