CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234175

Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Driveway Inspection Devon Perry Passed Wednesday, July 31,

2024

Informational:

1 Misc 7-22-24 DP. Crew was onsite pouring the driveway today. They did not call in

an inspection. They had rebar laying on the rock. They did have aggregate

down but didn't look very compacted from what I could see.

7-31-24 DP. Driveway is complete

Comments: