



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20113810, Building Permit - Commercial  
Address: 117 SE M 291 HWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mike Copeland	Failed	Monday, November 07, 2011

Corrective Action Required  
1 MISC

SECURE MC CABLE WITHIN 12 INCHES OF BOXES ABOVE CEILING.

DO NOT DROP TILE

<b>Hood/Duct Inspection</b>	Mike Copeland	Passed	Monday, November 07, 2011
-----------------------------	---------------	--------	---------------------------

**Comments:**